

**WATER PENETRATION RESISTANCE PERFORMANCE TEST IN
ACCORDANCE WITH ASTM-E331/ASTM-E547 TEST PROCEDURES**


PRODUCT MANUFACTURER
FERCO ARCHITECTURAL HARDWARE INC. 2000, rue Berlier Laval, Québec H7L 4S4 450-973-1437

REPORT AI-05093-A1 Rev.1


TEST REPORT SUMMARY	
Product type	Opaque Steel Door
Evaluated product	Handle sets with sealed gasket
Test results:	No water penetration until a difference of pressure of 720 Pa (15 psf) in accordance with ASTM E331/ASTM E547 test procedures

See CLEB laboratory Inc. complete report AI-05093-A1 Rev.1 for test specimen description and detailed test results

Test completion date	2019-03-18	Number of pages	4 pages & 1appendix
Report date	2019-03-21	Revision date	2019-04-10

Prepared by:


Digitally Signed by:
Luc Boyer, Tech.
 Fenestration Testing Department
 CLEB laboratory Inc.

Approved by:


Digitally Signed by:
Jean Miller, P.Eng.
 Manager, Fenestration Testing Department
 CLEB laboratory Inc

LABORATORY, FIELD TESTING AND ADVISORY SERVICES FOR THE BUILDING ENVELOPE
 30 YEARS STRONG, UL AND CLEB SERVING CUSTOMERS ACROSS NORTH AMERICA AND BEYOND

CHICAGO
 US Headquarters
 750 Anthony Trail
 Northbrook, IL 60062
 chicago@cleb.com

MONTREAL
 Canada Headquarters
 1320 Lionel-Boulet Blvd
 Varennes, QC J3X 1P7
 montreal@cleb.com

QUEBEC
 420 Charest East Blvd
 Suite 300
 Quebec, QC G1K 8M4
 quebec@cleb.com

OTTAWA
 29 Capital Drive
 Suite 200
 Ottawa, ON K2G 0E7
 ottawa@cleb.com

TRURO
 64 Inglis Place
 Suite 203
 Truro, NS B2N 4B4
 truro@cleb.com

NEW YORK
 747 Third Avenue
 2nd Floor
 New York, NY 10017
 newyork@cleb.com

T: 855.353.2532 W: ul.com/buildingenvelope