



**LIFT & SLIDE ROLLER  
ASSEMBLIES EVALUATION  
AS PER AAMA 906-21 STANDARD**

**PRODUCT MANUFACTURER**

**FERCO ARCHITECTURAL HARDWARE INC.**

2000, rue Berlier  
Laval, Québec  
H7L 4S4  
450-973-1437

**REPORT AS-01432**

**TEST REPORT SUMMARY**

<b>Product type</b>	Lift and slide roller
<b>Evaluated product</b>	Lift&Slide roller assembly GU-934 (K-16488-00-0-18) Lift&Slide roller assembly GU-934 Tandem (K-16488-00-0-18 + K-17804-01-0-18)
<b>Test results:</b>	The Lift&Slide roller assembly GU-934, as described in section 3 of AS-01432-A report, completed successfully the AAMA 906 standard requirements including cycling of 10 000 cycles with a load rating of 300 kg. The Lift&Slide roller assembly GU-934 Tandem, as described in section 3 of AS-01432-A report, completed successfully the AAMA 906 standard requirements including cycling of 10 000 cycles with a load rating of 600 kg.

See UL Laboratory Canada Inc. complete report AS-01432-A for test specimen description and detailed test results

<b>Test completion date</b>	2020-11-30	<b>Number of pages</b>	1 page
<b>Report date</b>	2021-04-02	<b>Revision date</b>	N/A

**Prepared by:**

  
**Justin Chagnon-Lafrance, Jr. Eng.**  
Project manager, Materials and Systems Testing  
UL Laboratory Canada Inc.

**Approved by:**

  
**Jean Loubert, P.Eng.**  
Assistant manager, Materials and Systems Testing  
UL Laboratory Canada Inc.

LABORATORY, FIELD TESTING AND ADVISORY SERVICES FOR THE BUILDING ENVELOPE  
125 YEARS STRONG, UL LABORATORY CANADA INC. SERVING CUSTOMERS ACROSS NORTH AMERICA AND BEYOND

**CHICAGO**  
US Headquarters  
750 Anthony Trail  
Northbrook, IL 60062

**MONTREAL**  
Canada Headquarters  
1320 Lionel-Boulet Blvd  
Varenes, QC J3X 1P7

**TORONTO**  
7, Underwriters Road  
Toronto, ON  
M1R 3A9